



- 1. Except for sidewalk joints, a conduit expansion fitting or expansion-deflection fitting shall be installed at each 12 mm or greater structure joint, hinge or abutment.
- 2. Fittings or combination of fittings shall be installed to accommodate the movement rating as shown on the structure plans.
- 3. Fittings shall be installed parallel to superstructure girders.
- 4. Where lateral movement greater than 6 mm may occur, a neoprene sleeve expansiondeflection fitting shall be installed straddling the joint.
- 5. The external bond strap may be omitted when the fitting is provided with an internal bond equivalent to a No. 6 copper bond in Type 1 conduit or the No. 8 equipment grounding conductor in Type 3 conduit.

DEPARTMENT OF TRANSPORTATION

ELECTRICAL SYSTEMS (ELECTRICAL DETAILS STRUCTURE INSTALLATIONS)

NO SCALE

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

ES-9B